SSO, Event Details Page 1 of 3



**Event Search** 

## Overflow / Bypass Event Details

Initial Report

Facility Name: Bolivar WWTF
Permit No: MO0022373

Once you enter the Event End Date & Time fields and Add Event/Save Changes, you will no longer be able t

1		
		Event Details
	Bypass =	at the wastewater treatment plant; Overflow = in the collectio
	Confirmation No:	1206
	*Type of Event:	Bypass
	*Wet or Dry Event?	Wet 🔽
	*Event Begin Date:	09/01/2012 (MM/DD/YYYY)
	*Event Begin Time:	17:15 (HH:MM) Military Time
	**Event End Date:	09/02/2012 (MM/DD/YYYY)
	**Event End Time:	08:00 (HH:MM) Military Time
	Event Duration (hh:mm)	0d:14h:45m:
	*Initial Report Date:	09/01/2012 (MM/DD/YYYY)
	*Initial Report Time:	19:37 (HH:MM) Military Time
	Discharged To:	Waterway
	*Reported By:	Joe Cornell
	*Immediate Contact	(417 ) 327 - 2763
	Ongoing?:	V
	*Estimated Volume at time of Initial Report (gallons):	1000.00
	Is bypass/overflow reaching Waters of the State?	
	Effected Waterbody:	Townbranch
	**Cause of Event:	Rain
	Cause of Event Comments:	

<sup>\*</sup> Indicates a Required Field

<sup>\*\*</sup>Indicates a Required Field for Final Report

SSO, Event Details Page 2 of 3

	Plant Hydraucally overloaded
Event Type:	Effluent Weir Flume
	$^{\star}$ To select more than one choice hold down the control key o
Additional Impact:	Fish Kill Public Beach or Public Use Area Impacted
	Dry Weather Release Drinking Water Intakes Affected
	Release Volume Greater Than 50,000 Gal
	Wet Event Details
*Wet Event Start Date:	08/31/2012 (MM/DD/YYYY)
**Wet Event End Date:	09/01/2012 (MM/DD/YYYY)
*Precipitation Type:	Rain
**Precipitation Amount (inches):	2.50
*Soil Conditions:	Saturated
	Location Information
County	
UTM Easting:	465405.783
UTM Northing:	4163189.149
* Location Description	1801 East Broadway
to another location. Select a county from the drop down to	ne slider may be used to zoom in or out. Use the pan buttons o zoom to that county.
County:	
Scale 1:2,400	
▼ Flag Icon	
Select the red indicator to activate the mark	ing tool then single click on the map to mark the location of yo

SSO, Event Details Page 3 of 3



5 - Day Report

\*\*Estimated Final Total Volume (gallons): 1300000.00

Did bypass reach Waters of the State?

\*\*Response: Test Results will follow



1-800-361-4827 / 573-751-1300 E-mail: cleanwater@dnr.mo.gov